



Group Northwest, Inc.

Geotechnical Engineers, Geologists, &
Environmental Scientists

13705 Bel Red Road
Bellevue, WA 98005-4517

Phone (425) 649-8757
Fax (425) 649-8758

FIELD REPORT

Job No.

G-3936

Date

9/5/2018

Page

1 of 1

Report No.

9

Project Name / Location

Summit Homes, Forest Heights, Lots 4 and 5


Permit No.

Lot 23

Bill Chang from GEO Group Northwest, Inc. conducted a site visit and performed geotechnical inspection for the subgrade of Lot 23.

We observed that the excavation extended into dense native soils. Some water seepage was observed to flow onto the lot from the adjacent Lot 22, but the seepage is channeled and will be controlled with the placement of filter fabric and crushed rock.

The subgrade for Lot 23 has been approved for placement of the filter fabric and crushed rock.



Copy to: Steve Moore - Summit Homes
Summit Homes - Dale Hart
File

Continued
on next page